



Jim Doyle, Governor
Jack L. Fischer, A.I.A., Secretary

April 8, 2008

NORTHERN DIVISION
REDMAN HOMES
RYAN E. MILES
308 SHERIDAN DR
TOPEKA IN 46571

Re: Description: PREFABRICATED PLUMBING SYSTEM
Manufacturer: NORTHERN DIVISION
Product Name: MODULAR HOME-DWV & WATER LINES
Model Number(s): MC 232-1/MC 233-1 4156 3 BR/2 BATH/FAMILY ROOM
Product File No: 20080158

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2013.

This approval is contingent upon compliance with the following stipulation(s):

- The flowing water supply pressure at the point(s) of connection must be at least 24 psig.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- The installation of air admittance valves must comply with the Wisconsin Department of Commerce plumbing product approval for the particular valve being installed.
- This approval is for only the prefabricated plumbing system as defined herein. "Prefabricated Plumbing" means concealed drain piping, vent piping or water supply piping or a combination of these types of piping, contained in a modular building component, which will not be visible for inspection when delivered to the final site of installation.

A copy of the approved plans and/or specifications is enclosed.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: Jerry.Thompson@wi.gov